

## CFEAODI - Over Door Indicator

### Device Overview and Specification

The CFEAODI Over Door Indicator forms part of the CFEAUPULLKIT Emergency Assist Alarm System.

Operating Voltage	12V dc (nominal)
Construction	PC
Dimensions (mm)	H 87 x W 87 x D 31.5

Note: Unit fits on to standard single gang back box



### Extra Low Voltage (ELV) Wiring

Always segregate low voltage wiring from the mains wiring.

System requires minimum 2 core 0.4mm<sup>2</sup> cable.

It should be noted that the wiring order of the various system components can be changed to suit a specific application and/or to reduce wiring runs.

All wall-mounting devices should be mounted onto a back box of the required depth.

### Wiring Guide Using 2 Core Cable

OUT	IN
PSU 12V supply	Over Door Indicator
Over Door Indicator	Cancel Unit
Cancel Unit	Pull Cord Unit

